

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

March 19, 2004

JOHNSON DIVERSEY TIM S. JONES 8310 16TH ST STURTEVANT WI 53177-0902 JOHNSON DIVERSEY WORLDWIDE R & D CHUCK SEAMAN 1525 HOWE STREET RACINE WI 53403-5011

Re: Description: PROPORTIONER
Manufacturer: JOHNSON DIVERSEY
Product Name: SOLUTIONS CENTER

Model Number(s): SOLO - 4385, SOLO AG - 4386, QUATTRO - 4346, QUATTRO AG - 4347, QUATTRO

SELECT AG AND FILL POINT

Product File No: 20040128

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2009.

This alternate approval is contingent upon compliance with the following stipulation(s):

• This product must be installed with a S.C. Johnson & Son, Inc., Flo-Thru device permanently connected to the inlet of the hose serving this product when this product is not served by a separate water supply connection.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 19970268.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wi.gov

SBD-10564-E (N.10/97) File Ref: 04012801.DOC